Purdue University Purdue e-Pubs

International Compressor Engineering Conference

School of Mechanical Engineering

2010

Noise Reduction Technology for Inverter Controlled Rotary Compressor

JianPing Huang Gree Electric Appliances

YuSheng Hu Gree Electric Appliances

SiHai Xia Gree Electric Appliances

Jia Xu Gree Electric Appliances

Follow this and additional works at: http://docs.lib.purdue.edu/icec

Huang, JianPing; Hu, YuSheng; Xia, SiHai; and Xu, Jia, "Noise Reduction Technology for Inverter Controlled Rotary Compressor" (2010). *International Compressor Engineering Conference*. Paper 1948. http://docs.lib.purdue.edu/icec/1948

Complete proceedings may be acquired in print and on CD-ROM directly from the Ray W. Herrick Laboratories at https://engineering.purdue.edu/Herrick/Events/orderlit.html

This document has been made available through Purdue e-Pubs, a service of the Purdue University Libraries. Please contact epubs@purdue.edu for additional information.

Noise Reduction Technology for Inverter Controlled Rotary Compressor

Jianping Huang, Yusheng Hu, Sihai Xia, Jia Xu

Compressor and Motor Institute of Gree Electric Appliance, Inc. of Zhuhai, Jinji West Rd., Zhuhai City, 519070, P. R. China Phone: 86-756-8668720, Fax: 86-756-8668982, E-mail: hjp_jean@163.com

ABSTRACT

Inverter controlled rotary compressor is taken as a study object. During 'run-up' a series of compressor noise are measured to determine the behavior of the structure and to determine the rotational speed, and the compressor noise at each operating speed is measured. Also modal analysis results show that the noise is caused by the resonance mode existing in the accumulator pipe. Based on the results of the noise experiment and modal analysis, a design change of the inner attachment of the accumulator using the dynamics modification theory has been done, and the undesired resonance mode is removed. Noise experiment of a compressor with the improved accumulator is performed, and not only a reduction of 5dB(A) in the noise of the compressor, but also a sound reduction of 15dB(A) in the resonance mode.

1. INTRODUCTION

To detect the noise source character, Sound power radiated from the compressor is measured, and during 'run-up' a compressor noise experiment is conducted.

To understand the structural characteristic of the compressor, FE model of the rotary compressor composed of all the components is built for the modal analysis. And a test modal analysis is conducted.

Based on the noise detection and modal analysis, a dynamics modification of the inner attachment of the accumulator has been done. Proposed design changes are applied and verified to eliminate aimed resonance modes in sound measurement experiment.

2. NOISE SOURCE DETERMINATION

During 'run-up' a compressor noise experiment is conducted, as shown in Figure 1. The results show that there is a noise mutation during the compressor's 'run-up'. Also a sound power versus the rotation speed of the compressor is measured, as shown in Figure 2, and the results show that there is a sound peak when the compressor is running at the speed of about 2700 rpm. Noise waterfall of a compressor is measured to determine the noise characteristic, as shown in Figure 3. The results show that there is a serious problem of noise caused by the coupling effect of the behavior of the structure and the rotational speed, which is marked with a red circle in Figure 3.



International High Performance Buildings Conference at Purdue, July 12-15, 2010



Figure 3 Noise Waterfall

3. MODAL ANALYSIS AND EXCITING FORCE DETERMINATION

To study the behavior of the structure, Impact modal tests are conducted. Based on the stabilization diagram shown in Figure 4, a modal frequency existing in the 1081.3Hz is found. This modal shape is shown in Figure 5. A study with finite element modal analysis is performed on a compressor. The calculated modal frequency is 1108.5Hz, and its modal shape is shown in figure 6.



International High Performance Buildings Conference at Purdue, July 12-15, 2010

1139, Page 3



Figure 6 Calculated Modal Shape

The error between the tested frequency and the calculated frequency is about 2.5%, and there is comparability between the tested mode and the calculated mode.

The compressor is equipped with a distributed winding motor, which is equipped with a 4-pole 24-slot IPM synchronous motor. The motor induces the 24-th harmonic magnetic force. When the compressor is operating at the speed of about 2700 rpm, the frequency of the 24-th harmonic magnetic force is 1080 Hz.

4. VERIFICATION WITH EXPERIMENT

The results of the noise experiment and modal analysis indicate that the 24-th harmonic magnetic force induces the resonance mode existing in the accumulator pipe, and the sound level become bad when the compressor is operating at the speed of 2700 rpm.

To validate it, a dynamics modification of the inner attachment of the accumulator has been done. The original accumulator is shown in Figure 7, and the modificatory accumulator is shown in Figure 8.

The undesired resonance mode is removed from 1080Hz. Noise experiment of a compressor with the improved accumulator is performed, and not only a reduction of 5dB(A) in the noise of the compressor, but also a sound reduction of 15dB(A) in the resonance mode of former accumulator has been confirmed, as shown in Figure 9.





Figure 7 Original Accumulator Figure 8 Modificatory Accumulator



5. CONCLUSIONS

The noise experiment results and modal analysis results show that a resonance modal frequency coincides with the 24-th harmonic magnetic force when the compressor is operating at the speed of 2700 rpm, which inducing the resonance mode existing in the accumulator pipe.

When the undesired resonance mode is removed, the noise level of the compressor is improved. When the compressor is running at the speed of 2700 rpm, not only a reduction of 5 dB(A) in the noise of the compressor, but also a sound reduction of 15 dB(A) in the resonance mode of former accumulator has been confirmed.

REFERENCES

Masanori Yanagisawa, Susumu Hiodoshi, Masao Saito, Shuji Ero, 2002, Noise reduction technology for inverter controlled scroll compressors, Proceedings Purdue Compressor Technology Conf., C18-5.

Semyung Wang, Jongchan Park, Insoo Hwang, Byoungha Kwon, 2002, Sound reduction of rotary compressor using topology optimization, Proceedings Purdue Compressor Technology Conf., C14-4.

Duo Wang, Jingwen Zhao, 1997, Theoretical Mechanics, China Higher Education Press, Beijing, p. 42-194. Guoyuan Ma, Hongqi, Li, 2001, Rotary Compressor, China Machine Press, Beijing, p. 22-80.