

1992

Design and Performance of a Gas-Fired Window Air Conditioner

B. Ghassemi
University of Isfahan; Iran

S. M. Mossavi
University of Isfahan; Iran

Follow this and additional works at: <http://docs.lib.purdue.edu/iracc>

Ghassemi, B. and Mossavi, S. M., "Design and Performance of a Gas-Fired Window Air Conditioner" (1992). *International Refrigeration and Air Conditioning Conference*. Paper 168.
<http://docs.lib.purdue.edu/iracc/168>

This document has been made available through Purdue e-Pubs, a service of the Purdue University Libraries. Please contact epubs@purdue.edu for additional information.

Complete proceedings may be acquired in print and on CD-ROM directly from the Ray W. Herrick Laboratories at <https://engineering.purdue.edu/Herrick/Events/orderlit.html>

DESIGN AND PERFORMANCE OF A GAS-FIRED
WINDOW AIR CONDITIONER

by

*

**

Dr. B-GHASSEMI AND Dr.S.M.MOSSAVI

University of ISFAHAN-IRAN

SUMMARY

The existing window air conditioners are based on the vapor compression system utilizing electric energy which is mainly produced by burning the fossil fuels especially in third world countries. There are many countries around the world rich in natural gas with distribution network, but short in electricity, while, due to the hot climate, the demand for window air conditioners is high. This paper presents a design, thermodynamics aspects, as well as some of the operational data of a gas fired window air conditioner based on Ammonia absorption system developed by authors.

The results obtained are promising and cost effective.

KEY WORDS

Absorption system, window Air Conditioner.

1-INTRODUCTION

The existing window air conditioners are based on vapor compression system employing hermetic compressor using electric energy. In spite of the simplicity of this system. There are some disadvantages in utilizing this machine especially in countries rich of natural gas but short in electric power, in short, these are :

a- High energy consumption, when considering the efficiency of the power generating plants are about 1/3 of the total fuel energy.

b- Compressor is practically noisy with negative effects on the resident comfort, where as the air conditioning aim is better comfort.

* Associate Professor University of Isfahan-Iran

** Assistant Professor University of Isfahan-Iran

This work describes the development of a window air conditioner utilizes direct heat, with low level of generated noise and vibrations, very reliable and possibly maintenance free.

2-MATERIAL AND METHODS

Although the concept of the absorption refrigeration system is not new and the detail, specifications of the system are available in literatures (1) , (2) and also, there are many well known manufacturers of this type of plant, but, little attempts are made in applying this concept to small air cooling unit (3). The cooling unit proposed in this paper is based on NH₃ absorption system, the required heat energy is taken directly by burning the natural gas with calorific values of 39980 KJ/m³ and pressure 17.8 cm water column, obtained from distribution pipe line. The boiler consist of a steel tube with 12 cm dia and 4 welded steel fin of 20 cm dia installed in the generator. Fig 1 presents the configuration and the main components of the machine, table (1) shows the summary of thermodynamics properties of the ammonia solution of the designed cycles, the highest temperature in the generator is 98 °C and the highest pressure in the cycles is 10 bar while the low pressure side is 1.7 in the Evaporator.

3-RESULTS AND DISCUSSION

The practical data and the C.O.P presented in Fig.2 (4) of about 0.5 obtained for this design reveals the possibility of using the ammonia absorption system for cooling the small residential area by this method of window air conditioner, although the weight of the unit is about 60 per cent more than the vapor compression system but is practically noiseless and maintenance free. The solution pump energy is about 200 watts and may be taken either from house electric network and or a rechargeable battery.

4-CONCLUSION AND SIGNIFICANT NEW FINDINGS OF THIS WORK

Application of this system for countries such as IRAN rich of natural gas and extended distribution network, but short of electricity has the following advantages.

- a- Saving on individual electricity bill as well as the capital cost on electricity generating plant, especially when considering that the cooling units are used for a period of 3 to 4 months per year.
- b- The system is noise less, simple and very reliable.

5-ACKNOWLEDGMENTS

The authors express their gratitude to the authorities of the University of Isfahan-Iran and the ministry of science and higher education for their financial support and their permission to publish this result.

We are indebted to the management of the Mahya Gas Co. of Isfahan-Iran for their permission to use their research workshop and experimental facilities.

6-REFERENCES

- 1- Stoker, W.F, 1988. Industrial refrigeration, business new publishing Co.Troy, MI.
- 2- Grossman, G and K.W. Childs. 1983. Computer simulation of a lithium Bromide-water Absorption heat pump for temperature boosting. ASHRAE Transactions 89(1).
- 3- GHASSEMI, B. 1987. Theoretical study of Absorption Refrigeration for vehicle Applications. Proc. 17th int. Congress of Refrigeration, Wien.
- 4- Ziegler, F. and Alefeld, G, 1987, Coefficient of performance of Multistage absorption cycles, int.J. of Refrigeration. 10.285.

TABLE (I)

THERMODYNAMIC PROPERTIES OF THE REFRIGERANT					
Exit point	P-bar	Toc	X	W	H Kj/Kg
Absorber	1.7	32	0.36	3.05	-111.5
Generator	10.2	98	0.93	0.22	1557.0
Return	10.2	98	0.32	2.83	248.6
Condenser	10.0	30	0.93	0.22	83.6
Evaporator	1.7	-1	0.93	0.22	1041.1

Summary of thermodynamics properties of aquamonia at different points of the designed cycles.

- P Pressure bar
- T Tempreture oc
- W Mass flow of the refrigerant Kg/min
- X Mass fraction
- H Enthalpy Kj/Kg




Figure 2




Fig. 1