

2016

Gradient-Based Estimation of Air Flow and Geometry Configurations in a Building Using Fluid Dynamic Adjoint Equations

Runxin He

Department of Electrical and Systems Engineering, Washington University in Saint Louis, United States of America,
runxinhe@email.wustl.edu

Humberto Gonzalez

Department of Electrical and Systems Engineering, Washington University in Saint Louis, United States of America,
hgonzale@wustl.edu

Follow this and additional works at: <http://docs.lib.purdue.edu/ihpbc>

He, Runxin and Gonzalez, Humberto, "Gradient-Based Estimation of Air Flow and Geometry Configurations in a Building Using Fluid Dynamic Adjoint Equations" (2016). *International High Performance Buildings Conference*. Paper 198.
<http://docs.lib.purdue.edu/ihpbc/198>

This document has been made available through Purdue e-Pubs, a service of the Purdue University Libraries. Please contact epubs@purdue.edu for additional information.

Complete proceedings may be acquired in print and on CD-ROM directly from the Ray W. Herrick Laboratories at <https://engineering.purdue.edu/Herrick/Events/orderlit.html>

Gradient-Based Estimation of Air Flow and Geometry Configurations in a Building Using Fluid Dynamic Adjoint Equations

Runxin HE^{1*}, Humberto GONZALEZ²

Department of Electrical & Systems Engineering, Washington University in St. Louis,
St. Louis, MO, USA

¹ runxinhe@email.wustl.edu

² hgonzale@wustl.edu

* Corresponding Author

ABSTRACT

Real-time estimations of temperature distributions and geometric configurations are important to energy efficient buildings and the development of smarter cities. In this paper we formulate a gradient-based estimation algorithm capable of reconstructing the states of doors in a building, as well as its temperature distribution, based on a floor plan and a set of thermostats. Our algorithm solves in real time a convection-diffusion Computer Fluid Dynamics (CFD) model for the air flow in the building as a function of its geometric configuration. We formulate the estimation algorithm as an optimization problem, and we solve it by computing the adjoint equations of our CFD model, which we then use to obtain the gradients of the cost function with respect to the flow's temperature and door states. We evaluate the performance of our method using simulations of an apartment in the St. Louis area. Our results show that the estimation method is both efficient and accurate, establishing its potential for the design of smarter control schemes in the operation of high-performance buildings.

1. INTRODUCTION

Buildings currently account for more than 40% of the total energy consumption in the U.S. (U.S. Department of Energy, 2012), and they cost \$130 billion in energy leakage and inefficiency (U.S. Green Building Council, 2014). For this reason many research groups have developed new control algorithms to improve the performance and efficiency of Heating, Ventilation, and Air Conditioning (HVAC) systems in buildings (Wang & Ma, 2008; Dounis & Caraiscos, 2009; Afram & Janabi-Sharifi, 2014; Shaikh, Nor, Nallagownden, Elamvazuthi, & Ibrahim, 2014).

Among the many control algorithms used in smart building applications, Model Predictive Control (MPC) stands out thanks to its flexible mathematical formulation, as well as its accurate and robust responses in real-world implementations (Huang, 2011; Xi, Poo, & Chou, 2007; Moroşan, Bourdais, Dumur, & Buisson, 2010). Moreover, MPC has become the standard for solving complex constrained multivariate control problems in process control applications (Afram & Janabi-Sharifi, 2014). MPC has been used in HVAC control applications such as zoned temperature control (J. Ma, Qin, Salisbury, & Xu, 2012; He & Gonzalez, 2016) and overall temperature regularization (Privara, Široký, Ferkl, & Cigler, 2011) among others, experimentally showing significant increments in energy efficiency.

MPC algorithms require the use of dynamical models, which are used as predictors. Compared to concentrated-parameter models such as the Resistance-Capacitance (RC) networks (Y. Ma, Kelman, Daly, & Borrelli, 2012), Computational Fluid Dynamics (CFD) models for building temperature control have a significant advantage since they naturally incorporate geometric and air flow information. Moreover, CFD models can accurately describe short time scales, allowing us to reflect indoor climate changes in minutes or even seconds (Jones & Whittle, 1992; Chow, 1996). Hence, using MPC with CFD models as predictors enables the study of control and estimation strategies beyond the standard temperature control, such as controlling fan speeds or finding the optimal location for thermostats.

However, due to the predictive nature of its formulation, MPC is sensitive to mismatches in the dynamic predic-

tion model and inaccurate initial state estimations, which might lead to steady-state offsets or even system instability (Faanes & Skogestad, 2005). Therefore MPC algorithms are usually implemented in coordination with estimation algorithms capable of inferring relevant parameters and initial conditions from sensor data, such as Kalman filters. Other optimization-based estimation algorithms have been developed, such as the results by Isakov (2006) in Partial Differential Equation (PDE) estimation. Banks et al. viewed the parameters for the inverse problem as random variables, and used probabilistic inference methods to estimate the desired parameters (Banks & Bihari, 2001; Banks, Holm, & Kappel, 2011). Gutman (1990) fully discretized a weak form of the Stokes Equations in time and space and identified the system's discontinuous parameters.

In this paper, we develop a gradient-based optimization method to estimate the doors' state and temperature distribution in the apartment. In particular, our contribution is twofold. First, we mathematically formulate a gradient-based estimation method to identify real-time indoor climate distribution and the apartment doors' states based on only thermostatic data. Second, we show the accuracy of our estimation method under a limited number of thermostats by simulating an apartment in the St. Louis area. Our results show that thermostatic information, when used together with CFD models, provide enough information to estimate most of the variables relevant for building climate control. In other words, a handful of thermostats can provide information, such as the configuration of doors, without the need to physically install extra sensors in a building.

The paper is organized as follows. The fluid dynamic model and finite element method are formulated in Section 2. We present the theoretical basis for our gradient-based estimation algorithm in Section 3. Finally, our simulation results are presented in Section 4.

2. COMPUTATIONAL FLUID DYNAMIC MODEL AND OPTIMIZATION PROBLEM

The kernel of our model is the incompressible Navier-Stokes equation, which is a good approximation for the coupling of temperature with free flow convection at atmospheric conditions (Awbi, 1989; Dobrzynski, Pironneau, & Frey, 2004). Throughout the paper we make two major simplifications to this model. First, we assume that the air flow behaves as a laminar fluid which reaches steady-state behavior much faster than the temperature in the building. Theoretical (Awbi, 2003) and experimental (Sun, Stowell, Keener, & Michel Jr., 2002) results have shown that turbulent flows are present in residential building, such as in the area around HVAC vents, yet their overall effect in the temperature distribution is negligible. Hence, we consider a stationary laminar Navier-Stokes equation to describe the fluid behavior, and a time-dependent equation to describe the temperature behavior. Second, we consider only two-dimensional air flows moving parallel to the ground. These assumptions reduce the accuracy of our model to some extent (van der Poel, Stevens, & Lohse, 2013), yet they allow us to significantly simplify the computational complexity of our CFD-based control design.

Let $\Omega \subset \mathbb{R}^2$ be the area of interest, assumed to be bounded and connected, and let $\partial\Omega$ be its boundary. Let $u: \Omega \rightarrow \mathbb{R}^2$ be the *stationary air flow velocity*, and $p: \Omega \rightarrow \mathbb{R}$ be the *stationary air pressure* in Ω . Also, given $T > 0$, let $T_e: \Omega \times [0, T] \rightarrow \mathbb{R}$ be the *temperature* in Ω . Then, following Landau and Lifshitz (1959), the non-dimensional temperature convection-diffusion model in Ω can be described by the following PDE:

$$\frac{\partial T_e}{\partial t}(x, t) - \nabla_x \cdot (\kappa(x) \nabla_x T_e(x, t)) + u(x) \cdot \nabla_x T_e(x, t) = g_{T_e}(x, t), \quad (1)$$

where $g_{T_e}: \Omega \times [0, T] \rightarrow \mathbb{R}$ represents the heat source in the room, $\kappa: \Omega \rightarrow \mathbb{R}$ is the *thermal diffusivity*, Pr is the *Prandtl number* of the air, Re is the *Reynolds number* of the air, and $\nabla_x = \left(\frac{\partial}{\partial x_1}, \frac{\partial}{\partial x_2} \right)^T$ is the *gradient operator*. The initial condition of the temperature is:

$$T_e(x, 0) = \pi_0(x), \quad \text{for } x \in \Omega. \quad (2)$$

Similarly, the non-dimensional stationary air flow in Ω is governed by the following incompressible Navier-Stokes stationary PDE:

$$-\frac{1}{Re} \Delta_x u(x) + (u(x) \cdot \nabla_x) u(x) + \nabla_x p(x) + \alpha(x) u(x) = g_u(x), \quad \text{and}, \quad (3)$$

$$\nabla_x \cdot u(x) = 0, \quad (4)$$

where $g_u: \Omega \rightarrow \mathbb{R}^2$ represents all the external forces applied to the air (such as fans), and $\Delta_x = \frac{\partial^2}{\partial x_1^2} + \frac{\partial^2}{\partial x_2^2}$ is the *Laplacian operator*. We introduce the *viscous friction coefficient* $a: \Omega \rightarrow \mathbb{R}$, following the technique in Gersborg-Hansen, Sigmund, and Haber (2005), to model different materials in Ω . Indeed, when the point x corresponds to a material that blocks air, we choose $\alpha(x) \gg u(x)$, which results in $u(x) \approx 0$. When the point x corresponds to air, then we choose $\alpha(x) = 0$.

The building's exterior wall are denoted by $\Gamma_w \subset \partial\Omega$, and the air inlet of the HVAC system is modeled as a gap in the wall, denoted $\Gamma_i \subset \partial\Omega$. Hence, $\Gamma_w \cup \Gamma_i = \partial\Omega$. The boundary condition for the temperature is:

$$T_e(x) \equiv T_A, \quad \text{for } x \in \partial\Omega, \quad (5)$$

where T_A is the *atmospheric temperature*. We only apply a boundary condition for the pressure equation at the inlet, setting $p(x) \equiv p_A$ for each $x \in \Gamma_i$, where p_A is the *atmospheric pressure*. We do not define a boundary condition for the air flow at the inlet Γ_i , and we set the air flow at the exterior wall as follows:

$$u(x) \equiv 0, \quad \text{for } x \in \Gamma_w. \quad (6)$$

We assume that there are n_t thermostats in the building. The i -th thermostat is located at $x_i \in \Omega$, and samples the temperature in a neighborhood averaged using the *bump weight function* $\Phi_i(x) = \sigma \exp(-(\rho^2 - \|x - x_i\|^2)^{-1})$ for $\|x - x_i\| < \rho$, and $\Phi_i(x) = 0$ otherwise, where $\sigma > 0$ is a normalization factor such that $\int_{\Omega} \Phi_i(x) dx = 1$.

We also assume that there are n_d doors in the building. We define $\theta_i \in \{0, 1\}$ as the configuration of the i -th door, i.e., $\theta_i = 1$ when the i -th door is open, and $\theta_i = 0$ when is closed. Let $\Omega_{\theta_i} \subset \Omega$ be the area occupied by the i -th door when it is closed, and let \mathbb{I}_i be the indicator function of Ω_{θ_i} , i.e., $\mathbb{I}_i(x) = 1$ for $x \in \Omega_{\theta_i}$, and $\mathbb{I}_i(x) = 0$ otherwise.

When the door configuration changes, so does the prediction generated by our CFD model in equations (1) and (3). In particular, the parameters α and κ change for each $x \in \Omega_{\theta_i}$ as a function of θ_i . We model this relation by defining $\alpha: \Omega \times \{0, 1\}^{n_d} \rightarrow \mathbb{R}$ and $\kappa: \Omega \times \{0, 1\}^{n_d} \rightarrow \mathbb{R}$ as follows:

$$\alpha(x, \theta) = \alpha_0 + \sum_{i=0}^{n_d} (1 - \theta_i) (\alpha_w - \alpha_0) \mathbb{I}_i(x), \quad \text{and} \quad \kappa(x, \theta) = \kappa_0 + \sum_{i=0}^{n_d} (1 - \theta_i) (\kappa_w - \kappa_0) \mathbb{I}_i(x), \quad (7)$$

where α_0 and κ_0 are the parameters for open air, while α_w and κ_w are the parameters for solid walls. Note that both α and κ are affine functions of $\theta \in \mathbb{R}^{n_d}$.

Now, using binary values for each θ_i means that our estimation algorithm will have to use combinatorial methods, which tend to scale poorly in both computation time and computational resources. To avoid this problem we relax the binary parameters $\theta_i \in \{0, 1\}$, instead allowing them to belong to the unit interval $[0, 1]$. Although for each θ_i only the extreme values have meaningful physical interpretations, non-integer values can theoretically be interpreted as averaged observations over the optimization horizon, as explained in Vasudevan, Gonzalez, Bajcsy, and Sastry (2013a, 2013b). For example, if throughout the optimization horizon a door is open half the time, and closed half the time, it is likely that we will observe $\theta_i \approx 0.5$. The relaxation of each θ_i is also important in our numerical calculations, since it transforms the optimization program from a mixed-integer program to a more convenient nonlinear format (Gersborg-Hansen et al., 2005).

Now we can formulate our main estimation algorithm to compute the door configuration θ and the initial temperature π_0 using the information from the n_t thermostats in the building. Given an arbitrary estimation time horizon, say $[0, T]$, we write our optimal estimation problem as follows:

$$\begin{aligned} \min_{\pi_0: \Omega \rightarrow \mathbb{R}, \theta \in \mathbb{R}^{n_d}} J(\pi_0, \theta) &= \sum_{i=1}^{n_t} \int_0^T \left(\int_{\Omega_i} \Phi_i T_e(x, t; \pi_0, \theta) dx - T_{e,i}^* \right)^2 dt + \eta_0 \sum_{i=1}^{n_t} \left(\int_{\Omega_i} \Phi_i \pi_0 dx - \pi_{0,i}^* \right)^2 + \eta_1 \|\pi_0\|_{\Omega}^2, \\ \text{subject to:} & \text{partial differential equations (1), (3), and (4),} \\ & \text{boundary and initial conditions (2), (5), and (6),} \\ & 0 \leq \theta_i \leq 1, \quad \forall i \in \{1, \dots, n_d\}, \end{aligned} \quad (8)$$

where, $\eta_0, \eta_1 > 0$ are weight parameters, $T_e(x, t; \pi_0, \theta)$ is the unique solution of equation (1) with initial condition π_0 and configuration θ , $T_{e,i}^*(t)$ is the time signal obtained from the i -th thermostat over the horizon $[0, T]$, and $\pi_{0,i}^*$ is just notation for the initial thermostat temperature, i.e., $\pi_{0,i}^* = T_{e,i}^*(0)$.

3. ADJOINT-BASED GRADIENT COMPUTATION

In this section we develop a numerical algorithm to solve the optimization problem defined in equation (8). We use a gradient-based optimization algorithm to find local minimizers of our optimization problem, where the gradients are computed using the adjoint equations of the CFD model, similar to the techniques in Gunzburger (2000) and Yang and Tomlin (2014). We then discretize the adjoint equations using the Finite Element Method (FEM), resulting in a practical algorithm which we test in Section 4.

3.1 Adjoint Equations and Fréchet Derivatives

In order to derive our CFD model's adjoint equations, first we need to write the *Lagrangian function* of the optimization problem (Giles & Pierce, 1997; Gunzburger, 2000). Let $\{\lambda_i\}_{i=1}^6$ be the set of *Lagrange multipliers*, or *adjoint variables*, each associated to one of the equations (1) to (6) and defined in its respective dual space. Then, the Lagrangian function of our optimal estimation problem is:

$$L(T_e, u, p, \pi_0, \theta, \{\lambda_i\}_{i=1}^6) = J(\pi_0, \theta) + \left\langle \lambda_1, \frac{\partial T_e}{\partial t} - \nabla_x \cdot (\kappa(x) \nabla_x T_e) + u \cdot \nabla_x T_e - g_{T_e} \right\rangle_{\Omega \times [0, T]} + \langle \lambda_4, T_e \rangle_{\partial \Omega \times [0, T]} + \left\langle \lambda_2, -\frac{1}{Re} \Delta_x u + (u \cdot \nabla_x) u + \nabla_x p + \alpha u - g_u \right\rangle_{\Omega} + \langle \lambda_3, \nabla_x \cdot u \rangle_{\Omega} + \langle \lambda_5, u \rangle_{\Gamma_w} + \langle \lambda_6, T_e(0, \cdot) - \pi_0 \rangle_{\Omega}, \quad (9)$$

where $\langle f_1, f_2 \rangle_S = \int_S f_1(z) f_2(z) dz$ is the inner product of the Hilbert space of square integrable functions $\mathcal{L}^2(S)$. We write the necessary conditions for optimality using Galerkin methods (Girault & Raviart, 1979), i.e., by setting the inner product of the partial derivatives of L with respect to all the dual directions equal to zero. That is, we look for solutions such that $\langle \frac{\partial L}{\partial T_e}, w \rangle_{\Omega \times [0, T]} = 0$, $\langle \frac{\partial L}{\partial u}, v \rangle_{\Omega} = 0$, and $\langle \frac{\partial L}{\partial p}, q \rangle_{\Omega} = 0$ for each set of functions (w, v, q) in the respective dual spaces, and sufficiently weakly differentiable. As detailed in Appendix A, the conditions above are satisfied when the dual variables satisfy:

$$-2 \sum_{i=1}^{n_t} \left(\int_{\Omega_i} \Phi_i(z) T_e(z, t) dz - T_{e,i}^*(t) \right) + \frac{\partial \lambda_1}{\partial t}(x, t) + \nabla_x \cdot (\kappa(x) \nabla_x \lambda_1(x, t)) + u(x) \cdot \nabla_x \lambda_1(x, t) = 0, \quad (10)$$

$$\lambda_6(x) = \lambda_1(x, 0), \quad (11)$$

$$\int_0^T \lambda_1(x, t) \nabla_x T_e(x, t) dt + \alpha(x) \lambda_2(x) - \frac{1}{Re} \Delta_x \lambda_2(x) - u(x) \cdot \nabla_x \lambda_2(x) + \lambda_2(x) \cdot \nabla_x u(x) - \nabla_x \lambda_3(x) = 0, \quad \text{and}, \quad (12)$$

$$\nabla_x \cdot \lambda_2(x) = 0, \quad (13)$$

with boundary conditions $\lambda_1(x, t) = 0$ and $\lambda_2(x, t) = 0$ for each $x \in \partial \Omega$ and $t \in [0, T]$, together with final condition $\lambda_1(x, T) = 0$ for each $x \in \Omega$. The adjoint functions λ_4 and λ_5 are irrelevant to our Fréchet derivative calculation, therefore we omit them from this presentation.

Now we can compute the Fréchet derivatives of the cost function with respect to θ and π_0 . Consider a parameter change from (θ, π_0) to $(\theta + \delta\theta, \pi_0 + \delta\pi_0)$. Since both α and κ are affine in θ , these variations will result in changes from (α, κ) to $(\alpha + \delta\alpha, \kappa + \delta\kappa)$, which will also imply changes from (T_e, u, p) to $(T_e + \delta T_e, u + \delta u, p + \delta p)$. As detailed in Appendix B, these variations allow us to compute a first-order approximation of the cost function J , which result in:

$$\langle \mathcal{D}_\alpha J, \delta\alpha \rangle_{\Omega} = \langle \lambda_2 \cdot u, \delta\alpha \rangle_{\Omega}, \quad \text{and} \quad \langle \mathcal{D}_\kappa J, \delta\kappa \rangle_{\Omega} = \int_0^T \langle \nabla_x \lambda_1 \cdot \nabla_x T_e, \delta\kappa \rangle_{\Omega} dt, \quad (14)$$

and using the chain rule and the formulas in equation (14) we get the desired directional derivatives for J :

$$\langle \mathcal{D}_{\pi_0} J, \delta\pi_0 \rangle_{\Omega} = \langle \nabla_{\pi_0} J - \lambda_6, \delta\pi_0 \rangle_{\Omega}, \quad \text{and} \quad \mathcal{D}_\theta J \cdot \delta\theta = \sum_{i=1}^{n_d} \left(\langle \mathcal{D}_\alpha J, \frac{\partial \alpha}{\partial \theta_i} \rangle_{\Omega} + \langle \mathcal{D}_\kappa J, \frac{\partial \kappa}{\partial \theta_i} \rangle_{\Omega} \right) \delta\theta_i. \quad (15)$$

Note that both directional derivatives are linear bounded operators, hence they are also Fréchet derivatives as desired.

Algorithm 1 Gradient-based estimation algorithm**Require:** Initial values for θ and π_0 .

- 1: **loop**
- 2: Compute T_e , u , and p by solving the CFD model in equations (1) to (6).
- 3: Compute λ_1 , λ_2 , λ_3 , and λ_6 by solving the adjoint equations (10) to (13).
- 4: Compute the gradients \mathcal{D}_{π_0} and \mathcal{D}_θ in equation (15).
- 5: Compute the projected-gradient descent directions $(\delta\pi_0, \delta\theta)$ by solving the QP in equation (16), with value V .
- 6: **if** $V = 0$ **then**
- 7: Stop.
- 8: **end if**
- 9: Compute the step size β using the Armijo line search method in equation (17).
- 10: Update $\pi_0 \leftarrow \pi_0 + \delta\pi_0$ and $\theta \leftarrow \theta + \beta \delta\theta$.
- 11: **end loop**

3.2 Gradient-Based Optimization Algorithm

Using the closed-form formulas for the Fréchet derivatives of J with respect to π_0 and θ , we build a gradient-based optimization algorithm to solve the problem in equation (8) using a projected-gradient method (Nocedal & Wright, 2006, Chapter 18.6).

First, we find descent directions $\delta\pi_0$ and $\delta\theta$ as solutions of the following Quadratic Program (QP) with value V :

$$V = \min_{\delta\pi_0: \Omega \rightarrow \mathbb{R}, \delta\theta \in \mathbb{R}^{n_d}} \langle \mathcal{D}_{\pi_0} J, \delta\pi_0 \rangle_\Omega + \mathcal{D}_\theta J \cdot \delta\theta + \frac{\gamma}{2} \|\delta\pi_0\|_\Omega^2 + \frac{\gamma}{2} \|\delta\theta\|^2, \quad (16)$$

subject to: $0 \leq \theta_i + \delta\theta_i \leq 1, \forall i \in \{1, \dots, n_d\}$,

where $\gamma > 0$ is a parameter. The QP in equation (16) is derived using first-order approximations for the cost function using the derivatives in equation (15), together with a condition to guarantee the feasibility of the desired direction. Note that $V \leq 0$, since $\delta\pi_0 = 0$ and $\delta\theta = 0$ always belong to the feasible set. Hence, if $V = 0$ then our method cannot find further descent directions, and it thus terminates.

Second, a step size is computed using the following Armijo line search method:

$$\beta = \arg \max_{j \in \mathbb{N}} \bar{\beta}^j, \quad (17)$$

subject to: $J(\pi_0 + \bar{\beta}^j \delta\pi_0, \theta + \bar{\beta}^j \delta\theta) - J(T_e, \pi_0, \theta) \leq \bar{\alpha} \bar{\beta}^j V$.

where $\bar{\alpha}, \bar{\beta} \in (0, 1)$ are parameters.

Our gradient-based optimization method is detailed in Algorithm 1. Steps 2 and 3, are numerically solved using FEM discretizations, implemented using the FEniCS package (Logg, Mardal, & Wells, 2012).

4. SIMULATION RESULTS

We applied our estimation algorithm to a simulated St. Louis area apartment with $n_d = 4$ doors, labeled $\{d_i\}_{i=1}^4$, and $n_t = 3$ thermostats, labeled $\{s_i\}_{i=1}^3$. The floor plan of the apartment is shown in Figure 1, with dimensions $7.6 \times 16.8 \text{ m}^2$ (approx. 1375 sq ft). The apartment is equipped with four HVAC vents, labeled $\{h_i\}_{i=1}^4$. We assume that each vent is endowed with a fan acting on a $1 \times 0.5 \text{ m}^2$ area, and oriented in a fixed direction.

The CFD model is governed by the constants $Re = 10^2$, $\alpha_0 = 0$, and $\kappa_0 = 10^{-2}$ when $x \in \Omega$ corresponds to free air, while $\alpha_w = 10^3$ and $\kappa_w = 10^{-4}$ when $x \in \Omega$ corresponds to a wall. The atmospheric pressure is $p_A = 101.3 \text{ kPa}$, and the atmospheric temperature is $T_A = 23.83 \text{ }^\circ\text{C}$. We assume that h_1 and h_2 work at a low output setting, producing 0.1 kW of heat and an air flow speed of 0.1 m/s. On the other hand, h_3 and h_4 work at a normal setting, producing 4 kW of heat and an air flow speed of 0.5 m/s. The time horizon is 300 s, sampled uniformly at 10 s steps. The sensors' observation radius is $r = 1.0 \text{ m}$. The parameters in (8) are set to $\eta_0 = 1.0$, $\eta_1 = 0.1$. The parameter in (16) is set to $\gamma = 1.0$. The parameters in (17) are set to $\bar{\alpha} = 0.01$ and $\bar{\beta} = 0.7$. We wrote our code in Python, the FEM discretization




Figure 1: Floor plan of the apartment simulated in Sec. 4.




Figure 2: Results of the experiments in Sec. 4.2. Columns: (B) Banks and Bihari's method, (G) Gradient-based method, Algorithm 1.

was computed using tools from the FEniCS Project (Logg et al., 2012), and the building plan was discretized into $n_{\text{elem}} = 6276$ elements.

4.1 Probabilistic Estimation Method

In our simulations below we compare our estimation method with a probabilistic-based estimation algorithm formulated by Banks and Bihari (2001), and applied to problems involving parameter estimation of differential equations (Banks et al., 2011). Under Banks and Bihari's framework, π_0 and θ are random variables with unknown probability distributions, thus the estimation problem is formulated to find the optimal distributions that would most likely produce the acquired sensor data in expectation. Due to space constraints we omit a detailed description of this method, and we refer interested readers to (Banks & Bihari, 2001).

Let $\pi_{0,\Delta}$ be the FEM discretization of π_0 , hence $\pi_{0,\Delta} \in \mathbb{R}^{n_{\text{elem}}}$. We assume that θ and $\pi_{0,\Delta}$ follow probability distributions $\mathbb{P}(\theta)$ and $\mathbb{P}(\pi_0)$. In the particular case of θ , since it is a vector of independent binary variables, its distribution is $\mathbb{P}(\theta) = \prod_{i=1}^{n_d} p_i^{\theta_i} (1 - p_i)^{1 - \theta_i}$. We assume that θ and $\pi_{0,\Delta}$ are independent.

Banks and Bihari's estimation algorithm relies on closed-form formulas of the expected values of each of the random variables in the cost function. Using the cost function in equation (8), the only nontrivial expected value is that of $T_{e,\Delta}(x, t; \pi_{0,\Delta}, \theta)$, the FEM discretization of T_e . Note that given $x \in \Omega$, $t \in [0, T]$, and $\theta \in \{0, 1\}^{n_d}$, then $T_{e,\Delta}(x, t; \pi_{0,\Delta}, \theta)$ is a linear function of $\pi_{0,\Delta}$; hence, as shown by Kumar and Varaiya (2015, Chapter 3), the conditional expected value of $T_{e,\Delta}$ is $\mathbb{E}[T_{e,\Delta}(x, t; \pi_{0,\Delta}, \theta) \mid \theta] = T_{e,\Delta}(x, t; \mathbb{E}[\pi_{0,\Delta}], \theta)$ for each pair (x, t) . Then, using Bayes' rule,

$$\mathbb{E}[T_{e,\Delta}(x, t; \pi_{0,\Delta}, \theta)] = \sum_{\theta \in \{0,1\}^{n_d}} T_{e,\Delta}(x, t; \mathbb{E}[\pi_{0,\Delta}], \theta) \mathbb{P}(\theta), \quad \forall x \in \Omega, t \in [0, T]. \quad (18)$$

It is worth noting that the cardinality of $\{0, 1\}^{n_d}$ is 2^{n_d} , hence each evaluation of equation (18) involves solving a PDE an exponentially growing number of times as a function of n_d .

4.2 Estimation Using Three Thermostats

We run both estimation algorithms, Banks and Bihari's method and gradient-based method, Algorithm 1, under six different combinations for $\theta \in \{(0, 0, 0, 0), (0, 0, 1, 1), (0, 1, 1, 0), (0, 1, 1, 1), (1, 0, 0, 0), (1, 1, 1, 1)\}$ and two different initial temperatures π_0 . Since Algorithm 1 converges to local minimizers, we also run five estimations for each pair (π_0, θ) initializing the algorithm with different values.

Figure 2a is a bar plot of the average estimation errors of θ , calculated as $e_\theta = \frac{1}{n_d} \sum_{i=1}^{n_d} |\theta_i - \hat{\theta}_i|$, where $\hat{\theta}$ is either the estimated probability distribution from Banks and Bihari's method, or the estimated relaxed configuration from gradient-based method, Algorithm 1. Figure 2b shows a similar bar plot for the relative estimation error of π_0 , calculated as $e_{\pi_0} = \frac{\|\pi_0 - \hat{\pi}_0\|_\Omega}{\|\pi_0\|_\Omega}$, where $\hat{\pi}_0$ is either the estimated expected value of π_0 from Banks and Bihari's method, or the estimated




Figure 3: Results of the experiments in Sec. 4.2. All doors are closed.




Figure 4: Results of the experiments in Sec. 4.3. Columns: (B) Banks and Bihari's method, (G) Gradient-based method, Algorithm 1.




Figure 5: Memory usage in GB of the experiments in Sec. 4.4.

initial distribution from gradient-based method, Algorithm 1. From these results we can observe that Algorithm 1 is significantly more accurate than the probabilistic method in estimating both doors' states and initial temperature distribution. It is worth noting that the average error of gradient-based method, Algorithm 1, in Figure 2a is small enough so that one can use a constant threshold to convert from relaxed values of θ to binary values. Also, the accuracy of our results enables further smart applications, such as the locating the residents in a building by using thermostat data and further behavioural assumptions. In Figure 3 we show the actual initial temperature distribution for one configuration θ , and the estimation errors by both algorithms. These results show that even with the temperature of three points, the gradient-based method, Algorithm 1, can accurately reconstruct the initial temperature distribution in the building, thus enabling advanced control methods such as MPC to significantly improve the energy efficiency of the HVAC system (He & Gonzalez, 2016).

4.3 Estimation Using One Thermostat

Now we only assume that only one thermostat, s_1 , is functional. The motivation is to show the performance of both estimation algorithms in a realistic scenario, since most residential buildings' HVAC systems operate using a single thermostat. We simulated the same scenarios as in Section 4.2.

Figures 4a and 4c are analogous to those in Figure 2, while Figure 4b shows the estimation error just for door d_1 , which is located very close to thermostat s_1 . As shown in these figures, both estimation algorithms do an almost equally poor job at estimating the doors' states, and the gradient-based method, Algorithm 1, is marginally better at estimating the initial temperature distribution. Yet, both algorithms are capable of accurately estimating the configuration of the door closest to the thermostat.

4.4 Memory usage comparison

A significant advantage of the gradient-based method, Algorithm 1, when compared to probabilistic estimation algorithms is that our method does not need to compute numerical solutions of the set of differential equations for each possible configuration $\theta \in \{0, 1\}^{n_d}$. Figure 5 shows the maximum memory usage of both algorithm implementations as the number of doors to estimate increases from 1 to 4. Our results show that the probabilistic estimation method can be used only for small values of n_d , quickly outgrowing the amount of memory in standard computers (for $n_d = 4$ the usage was 16 GB approx.), while Algorithm 1 memory usage remains almost constant (at 2.4 GB approx.).

5. CONCLUSION

Our gradient-based estimation method and simulation results show the potential for reconstructing indoor climate and building configuration by using only thermostat sensor data, thus reducing the need for extra sensors to monitor a smart buildings. Also, since the method can accurately estimate the indoor climate and configuration with acceptable memory usage, it can be used in coordination to advanced MPC control strategies, significantly increasing the efficiency of HVAC units without a decrease in human comfort. Our method has the potential to enable interesting new applications. For example, since it is able to identify a building's configuration in real-time, it can potentially be applied to monitor an unexpected break-in.

A. DERIVATION OF ADJOINT EQUATIONS

Consider the Lagrangian function in equation (9). For each set of functions (w, v, q) in the respective dual space of the tuple (T_e, u, p) , we can write $\langle \frac{\partial L}{\partial T_e}, w \rangle_{\Omega \times [0, T]} = 0$ as follows:

$$\left\langle \frac{\partial L}{\partial T_e}, w \right\rangle_{\Omega \times [0, T]} = \left\langle \frac{\partial J}{\partial T_e}, w \right\rangle_{\Omega \times [0, T]} + \left\langle \lambda_1, \frac{\partial w}{\partial t} - \nabla_x \cdot (\kappa \nabla_x w) + u \cdot \nabla_x w \right\rangle_{\Omega \times [0, T]} + \langle \lambda_4, w \rangle_{\partial \Omega \times [0, T]} + \langle \lambda_6, w(0, \cdot) \rangle_{\Omega} = 0. \quad (19)$$

Similarly, we can write $\langle \frac{\partial L}{\partial u}, v \rangle_{\Omega} = 0$ as

$$\left\langle \frac{\partial L}{\partial u}, v \right\rangle_{\Omega} = \left\langle \lambda_1, v \cdot \nabla_x T_e \right\rangle_{\Omega \times [0, T]} + \left\langle \lambda_2, -\frac{1}{Re} \Delta_x v + (u \cdot \nabla_x) v + (v \cdot \nabla_x) u + \alpha v \right\rangle_{\Omega} + \langle \lambda_3, \nabla_x \cdot v \rangle_{\Omega} + \langle \lambda_5, v \rangle_{\Gamma_w} = 0, \quad (20)$$

and we can write $\langle \frac{\partial L}{\partial p}, q \rangle_{\Omega} = 0$ as $\langle \lambda_2, \nabla_x q \rangle_{\Omega} = 0$.

Applying integration by parts and Green's formula, equations (19) and (20) become

$$\begin{aligned} \left\langle \frac{\partial J}{\partial T_e}, w \right\rangle_{\Omega \times [0, T]} - \left\langle \frac{\partial \lambda_1}{\partial t} + \nabla_x \cdot (\kappa \nabla_x \lambda_1) + u \cdot \nabla_x \lambda_1, w \right\rangle_{\Omega \times [0, T]} + \langle \lambda_1(\cdot, T), w(\cdot, T) \rangle_{\Omega} + \\ + \langle \lambda_6 - \lambda_1(\cdot, 0), w(\cdot, 0) \rangle_{\Omega} + \left\langle \kappa \frac{\partial \lambda_1}{\partial \bar{n}} + \lambda_4 + \bar{n} \cdot u \lambda_1, w \right\rangle_{\partial \Omega \times [0, T]} - \left\langle \kappa \lambda_1, \frac{\partial w}{\partial \bar{n}} \right\rangle_{\partial \Omega \times [0, T]} = 0, \quad (21) \end{aligned}$$

$$\begin{aligned} \langle \lambda_1, v \cdot \nabla_x T_e \rangle_{\Omega \times [0, T]} + \left\langle \alpha \lambda_2 - \frac{1}{Re} \Delta_x \lambda_2 + \nabla_x u \cdot \lambda_2 - u \cdot \nabla_x \lambda_2 - \nabla_x \lambda_3, v \right\rangle_{\Omega} + \\ - \frac{1}{Re} \langle \lambda_2, \frac{\partial v}{\partial \bar{n}} \rangle_{\partial \Omega} + \left\langle \frac{1}{Re} \frac{\partial \lambda_2}{\partial \bar{n}} + \lambda_3 \bar{n} + (u \cdot \bar{n}) \lambda_2, v \right\rangle_{\partial \Omega} + \langle \lambda_5, v \rangle_{\Gamma_w} = 0, \quad (22) \end{aligned}$$

where \bar{n} is the vector normal to the boundary at $x \in \partial \Omega$.

From the identities above it follows that, in order to make $\langle \frac{\partial L}{\partial T_e}, w \rangle_{\Omega \times [0, T]}$, $\langle \frac{\partial L}{\partial u}, v \rangle_{\Omega}$, and $\langle \frac{\partial L}{\partial p}, q \rangle_{\Omega}$ all equal to 0 for any set of functions (w, v, q) , a sufficient condition for the dual variables $\lambda_{1,2,3,6}$ is to satisfy the differential equations (10) to (13) and their boundary conditions.

B. DERIVATION OF FRÉCHET DERIVATIVES

As explained in Section 3.1, if we take variations $(\delta\pi_0, \delta\theta)$ of our optimization variables, they will induce variations $\delta\alpha$, $\delta\kappa$, δT_e , δu , and δp . Then, from equations (1), (3), and (4), it follows that the variations satisfy the following differential equations:

$$\frac{\partial \delta T_e}{\partial t} - \nabla_x \cdot (\delta\kappa \nabla_x T_e) - \nabla_x \cdot (\kappa \nabla_x \delta T_e) + \delta u \cdot \nabla_x T_e + u \cdot \nabla_x \delta T_e = 0, \quad (23)$$

$$\delta\alpha u + \alpha \delta u - \frac{1}{Re} \Delta_x \delta u + \delta u \cdot \nabla_x u + u \cdot \nabla_x \delta u + \nabla \delta p = 0, \quad (24)$$

$$\nabla_x \cdot \delta p = 0, \quad (25)$$

with the following boundary and initial conditions: $\delta T_e(x, t) = 0$ for each $x \in \partial\Omega$ and $t \in [0, T]$, $\delta T_e(x, 0) = \delta\pi_0(x)$ for each $x \in \Omega$, and $\delta u(x) = 0$ for each $x \in \Gamma_w$.

Now, using equations (8), (23), (24) and (25) and their boundary and initial conditions, we get

$$\begin{aligned} J(\theta + \delta\theta, \pi_0 + \delta\pi_0) - J(\theta, \pi_0) &= \left\langle \frac{\partial J}{\partial T_e}, \delta T_e \right\rangle_{\Omega \times [0, T]} + \left\langle \frac{\partial J}{\partial \pi_0}, \delta\pi_0 \right\rangle_{\Omega} + \\ &+ \left\langle \lambda_1, \frac{\partial \delta T_e}{\partial t} - \nabla_x \cdot (\delta\kappa \nabla_x T_e) - \nabla_x \cdot (\kappa \nabla_x \delta T_e) + \delta u \cdot \nabla_x T_e + u \cdot \nabla_x \delta T_e \right\rangle_{\Omega \times [0, T]} + \\ &+ \left\langle \lambda_2, \delta\alpha u + \alpha \delta u - \frac{1}{Re} \Delta_x \delta u + \delta u \cdot \nabla_x u + u \cdot \nabla_x \delta u + \nabla_x \delta p \right\rangle_{\Omega} + \left\langle \lambda_3, \nabla_x \cdot \delta u \right\rangle_{\Omega} + \\ &+ \left\langle \lambda_4, \delta T_e \right\rangle_{\partial\Omega \times [0, T]} + \left\langle \lambda_5, \delta u \right\rangle_{\Gamma_w} + \left\langle \lambda_6, \delta T_e(\cdot, 0) - \delta\pi_0 \right\rangle_{\Omega}, \quad (26) \end{aligned}$$

where $\{\lambda_i\}_{i=1}^6$ are the adjoint variables defined in Section 3.1. Then, applying integration by parts and Green's formula to equation (26), and after canceling terms using the identities in equations (10) to (13), we can get

$$J(\theta + \delta\theta, \pi_0 + \delta\pi_0) - J(\theta, \pi_0) = \left\langle \nabla_{\pi_0} J - \lambda_6, \delta\pi_0 \right\rangle_{\Omega} + \left\langle \nabla_x \lambda_1 \cdot \nabla_x T_e, \delta\kappa \right\rangle_{\Omega \times [0, T]} + \left\langle \lambda_2 \cdot u, \delta\alpha \right\rangle_{\Omega}, \quad (27)$$

which are equivalent to the directional derivatives in equations (14) and (15), as desired.

REFERENCES

- Afram, A., & Janabi-Sharifi, F. (2014). Theory and applications of HVAC control systems—a review of model predictive control (MPC). *Building and Environment*, 72, 343–355.
- Awbi, H. B. (1989). Application of computational fluid dynamics in room ventilation. *Building and Environment*, 24(1), 73–84.
- Awbi, H. B. (2003). *Ventilation of buildings*. Taylor & Francis.
- Banks, H. T., & Bihari, K. L. (2001). Modelling and estimating uncertainty in parameter estimation. *Inverse Problems*, 17(1).
- Banks, H. T., Holm, K., & Kappel, F. (2011). Comparison of optimal design methods in inverse problems. *Inverse Problems*, 27(7).
- Chow, W. (1996). Application of computational fluid dynamics in building services engineering. *Building and Environment*, 31(5), 425 - 436.
- Dobrzynski, C., Pironneau, O., & Frey, P. (2004). Numerical Coupling for Air Flow Computations in Complex Architectures. In *Proceedings of the european congress on computational methods in applied sciences and engineering (ecomas)*.
- Dounis, A. I., & Caraiscos, C. (2009). Advanced control systems engineering for energy and comfort management in a building environment—A review. *Renewable and Sustainable Energy Reviews*, 13(6), 1246–1261.
- Faanes, A., & Skogestad, S. (2005). Offset-free tracking of model predictive control with model mismatch: Experimental results. *Industrial & Engineering Chemistry Research*, 44(11), 3966–3972.
- Gersborg-Hansen, A., Sigmund, O., & Haber, R. B. (2005). Topology optimization of channel flow problems. *Structural and Multidisciplinary Optimization*, 30(3), 181–192.

- Giles, M. B., & Pierce, N. A. (1997). Adjoint equations in CFD: duality, boundary conditions and solution behaviour. In *Proceedings of the 13th computational fluid dynamics conference*.
- Girault, V., & Raviart, P.-A. (1979). *Finite element approximation of the Navier-Stokes equations*. Springer-Verlag.
- Gunzburger, M. (2000). Adjoint equation-based methods for control problems in incompressible, viscous flows. *Flow, Turbulence and Combustion*, 65(3-4), 249–272.
- Gutman, S. (1990). Identification of discontinuous parameters in flow equations. *SIAM Journal on Control and Optimization*, 28(5), 1049–1060.
- He, R., & Gonzalez, H. (2016). *Zoned HVAC control via PDE-constrained optimization*. (To appear in Proceedings of the 2016 American Control Conference. arXiv: 1504.04680)
- Huang, G. (2011). Model predictive control of VAV zone thermal systems concerning bi-linearity and gain nonlinearity. *Control Engineering Practice*, 19(7), 700–710.
- Isakov, V. (2006). *Inverse problems for partial differential equations*. Springer.
- Jones, P. J., & Whittle, G. E. (1992). Computational fluid dynamics for building air flow prediction—Current status and capabilities. *Building and Environment*, 27(3), 321–338.
- Kumar, P. R., & Varaiya, P. (2015). *Stochastic systems: Estimation, identification, and adaptive control*. SIAM.
- Landau, L. D., & Lifshitz, E. M. (1959). *Course of theoretical physics, volume 6: Fluid mechanics* (1st ed.). Pergamon Press.
- Logg, A., Mardal, K.-A., & Wells, G. (2012). *Automated solution of differential equations by the finite element method: The FEniCS book*. Springer.
- Ma, J., Qin, J., Salsbury, T., & Xu, P. (2012). Demand reduction in building energy systems based on economic model predictive control. *Chemical Engineering Science*, 67(1), 92–100.
- Ma, Y., Kelman, A., Daly, A., & Borrelli, F. (2012). Predictive control for energy efficient buildings with thermal storage. *IEEE Control System Magazine*, 32(1), 44–64.
- Moroşan, P.-D., Bourdais, R., Dumur, D., & Buisson, J. (2010). Building temperature regulation using a distributed model predictive control. *Energy and Buildings*, 42(9), 1445–1452.
- Nocedal, J., & Wright, S. (2006). *Numerical optimization*. Springer.
- Privara, S., Široký, J., Ferkl, L., & Cigler, J. (2011). Model predictive control of a building heating system: The first experience. *Energy and Buildings*, 43(2), 564–572.
- Shaikh, P. H., Nor, N. B. M., Nallagownden, P., Elamvazuthi, I., & Ibrahim, T. (2014). A review on optimized control systems for building energy and comfort management of smart sustainable buildings. *Renewable and Sustainable Energy Reviews*, 34, 409 - 429.
- Sun, H., Stowell, R. R., Keener, H. M., & Michel Jr., F. C. (2002). Two-dimensional computational fluid dynamics (CFD) modeling of air velocity and ammonia distribution in a high-rise hog building. *Transactions of the American Society of Agricultural and Biological Engineers*, 45(5), 1559–1568.
- U.S. Department of Energy. (2012, March). *2011 Buildings Energy Data Book*. Retrieved from http://buildingsdatabook.eren.doe.gov/docs/DataBooks/2011_BEDB.pdf
- U.S. Green Building Council. (2014). *Better Buildings, Better Policy: A compilation of green building policy adoptions in the United States, 2011-2014*. Retrieved from <http://www.usgbc.org/resources/better-buildings-better-policy-compilation-green-building-policy-adoptions-united-states-2>
- van der Poel, E. P., Stevens, R. J., & Lohse, D. (2013). Comparison between two- and three-dimensional Rayleigh-Bénard convection. *Journal of Fluid Mechanics*, 736, 177–194.
- Vasudevan, R., Gonzalez, H., Bajcsy, R., & Sastry, S. S. (2013a). Consistent approximations for the optimal control of constrained switched systems—Part 1: A conceptual algorithm. *SIAM Journal on Control and Optimization*, 51(6), 4463–4483.
- Vasudevan, R., Gonzalez, H., Bajcsy, R., & Sastry, S. S. (2013b). Consistent approximations for the optimal control of constrained switched systems—Part 2: An implementable algorithm. *SIAM Journal on Control and Optimization*, 51(6), 4484–4503.
- Wang, S., & Ma, Z. (2008). Supervisory and optimal control of building HVAC systems: A review. *HVAC&R Research*, 14(1), 3–32.
- Xi, X.-C., Poo, A.-N., & Chou, S.-K. (2007). Support vector regression model predictive control on a HVAC plant. *Control Engineering Practice*, 15(8), 897–908.
- Yang, I., & Tomlin, C. J. (2014). Reaction-diffusion systems in protein networks: Global existence and identification. *Systems & Control Letters*, 74, 50–57.