2008

Flow Patterns During Convective Boiling in Microchannels

T. Harirchian

S V. Garimella

Purdue University, sureshg@purdue.edu

Follow this and additional works at: <http://docs.lib.purdue.edu/coolingpubs>

Harirchian, T. and Garimella, S V., "Flow Patterns During Convective Boiling in Microchannels" (2008). *CTRC Research Publications*. Paper 270.

<http://docs.lib.purdue.edu/coolingpubs/270>

This document has been made available through Purdue e-Pubs, a service of the Purdue University Libraries. Please contact epubs@purdue.edu for additional information.

Flow patterns in 2200 μm x 400 μm microchannels (6000 fps)

Flow patterns in 400 μm x 400 μm microchannels (8000 fps)

Flow patterns in 5850 μm x 400 μm microchannels (2000-4000 fps)

Flow Patterns During Convective Boiling in Microchannels

T. Harirchian and S. V. Garimella

NSF Cooling Technologies Research Center

School of Mechanical Engineering, Purdue University, West Lafayette, IN 47907-2088

To develop a flow regime map for convective boiling in microchannels and to propose flow pattern-based models to predict the corresponding heat transfer coefficients, a thorough understanding of the existing flow patterns and their transitions is necessary. In the present study, high-speed photography is employed to observe the flow patterns in flow boiling of a dielectric liquid, FC-77, in parallel silicon microchannels of depth 400 μm and widths ranging from 100 to 5850 μm . In each test, liquid mass flux and inlet subcooling are fixed at 250 $\text{kg/m}^2\text{s}$ and 5°C, respectively, while the heat flux to the bottom of the heat sink is increased from zero to a value near the critical heat flux. Temperature and pressure are measured at several locations. A high-speed digital video camera is used to observe boiling patterns at frame rates ranging from 2000 to 24000 frames per second (fps). The images presented show a top view of the horizontal microchannels, at a location along the heat sink centerline and near the flow exit.